

# *Huawei*

*H19-371\_V1.0  
HCSA-Presales-Digital Power*



**For More Information – Visit link below:**

**<https://www.examsboost.com/>**

## **Product Version**

- ✓ **Up to Date products, reliable and verified.**
- ✓ **Questions and Answers in PDF Format.**

---

# Latest Version: 6.0

## Question: 1

The fire-fighting measures that can be used in the Class A computer room include:

- A. Gas Fire Extinguishing System
- B. Water mist fire extinguishing system
- C. Automatic sprinkler system
- D. All of the above

**Answer: A**

## Question: 2

The water inlet gradient of the condensate pan of the fan coil unit should not be less than ?

- A. 0.01
- B. 0.02
- C. 0.05
- D. 0.1

**Answer: A**

## Question: 3

The UPS5000-E power module adopts the fan fault-tolerant design. When two of the fans are damaged, what percentage of the load can the power module still carry?

- A. 0.2
- B. 0.3
- C. 0.5
- D. 0.6

**Answer: B**

## Question: 4

What is the total IT load power of the FusionModule1000A V2R3 version 40-foot IT solution?

- 
- A. 52kW
  - B. 55kW
  - C. 70kW
  - D. 72kW

**Answer: A**

### Question: 5

Which of the following models can be equipped with an external high-capacity battery charger for fast recharging? ()

- A. UPS5000-A
- B. UPS5000-E
- C. UPS2000-A 6/10K Professional Labeling Machine
- D. UPS2000-G 6K long

**Answer: C**

---

# Thank You for Trying Our Product

Discount Coupon Code:

**EXAMSBOOST10**

For More Information – **Visit link below:**

**<http://www.examsboost.com/>**



## FEATURES

- ✓ **90 Days Free Updates**
- ✓ **Money Back Pass Guarantee**
- ✓ **Instant Download or Email**

### Attachment

- ✓ **24/7 Live Chat Support**
- ✓ **PDF file could be used at any**

### Platform

- ✓ **50,000 Happy Customer**